
Architectural Series, Fire Protection Cabinet, Clear VU - C1516F25FX2 FE FX2 CABINET, CLEARVU, 1-1/2" SQ TRIM, FULL VIEW, CLR BUBL, CRS TUB, CRS DR/TRM, ALL WHT, 15 TUB



SPECIFICATIONS:

Tub Material: 24 gauge galvanized steel Trim Material & Style: 20 gauge CRS, semi-recessed 1-1/2" square edge

Door Material & Style: 20 gauge CRS, full view Flange Material: 22 gauge galvannealed steel **Glazing:** 0.090" clear polycarbonate bubble (8-½" x 22-½") **Finish:** Powder coat white door and trim, painted white tub Hinge: Continuous hinge opens door 180 degrees, 20 gauge CRS powder coat white

Hardware: Zinc plated pull handle, roller catch, glass clips &

Rough Opening: 12-13/16" x 26-5/16" x 3-11/16" Fire Rating: UL classified and labeled up to 2 hours in accordance with UL 1479 (ASTM-E814) and CAN/USC-S115. **Insulation:** Wool insulation

ADA Compliant: Cabinet meets 4" maximum protrusion, locate handle maximum 48" above floor

Compatible Extinguisher: Cosmic 2.5lb. - 10lb., Galaxy 2.5lb -10lb., Mercury 2.5lb. - 5lb., Sentinel 5lb.

MODEL # BREAKDOWN:

- C Product Line: Fire protection, cabinet
- 15 Tub Size: 10-½" x 24" x 4"
- 1 Trim and Door Material: CRS, powder coat finish
- 6 Trim Style: Semi-recessed 1-½" square edge
- F Door Style: Full view, pull handle, roller catch
- 25 Door Glazing: 0.090" clear polycarbonate bubble
- Color: All white

REPLACEMENT PARTS:

Tub: TUB-15-PP Trim: T-1016 Door: D-101F Glazing: BCV10F25 Hardware Pack: HPFPUS

MODEL #: C1516F25FX2

	800-554-6077	Distributor: Contractor:		Project:		
	🔀 sales@activarcpg.com			Approved By:		
	www.activarcpg.com	Date:	Quantity:	Architect:		
9702 Newton Ave S. Bloomington, MN 554	431 Many Locations Nationwide	Scale: 1:7.75	Pages: 1 OF 1	Drawing #:	C1516F25FX2-SUBMITTAL	
2024 Activar Construction Products Group, Inc. The information contained in this drawing is the sole property of activar construction products group, inc. any reproduction in part or as a whole without the written permission of activar construction products group, inc. is prohibited.						11/21/2024